

SPESIFIKASI BARANG/LINGKUP PEKERJAAN
JASA YANG DITAWARKAN

NO	NAMA BARANG/JASA	JUMLAH	SATUAN	HARGA SATUAN (Rp)	JUMLAH HARGA (Rp)
1.	Pengadaan Jasa dan Material Pemeliharaan Rutin CEMS PLTU Amurang Tahun 2023				
	Material (1 year operation)				
	a. Kit for Sec Probe	1	Lot		
	- Equipped Filter Cartridge (P01-0856-B)				
	- O-Ring ID 12 x 1.5 Fluoroelastomer (G06-012_0-1_5-V)				
	b. Kit for SEC Box				
	- Ceramic Cartridge 0,8 µm (F05-0253-A)				
	- FPM O-ring Øint 15 X 3,0 (G06-015_0-3_0-V)				
	- FPM O-ring Øint 22,5 X 2,0 (G06-022_5-2_0-V)				
	- Permeation dryer 6,94 m (F05-PERM-006-A)				
	c. Kit for MIR9000				
	- 5 µm Syringe filter 25 mm dia F06-0226-A				
	- Maintenance kit for pump V02-K113-909-A				
	- Dust filter power fan F05-0206-A				
	- Motor for IR Source (D01-1192-B)				
	- Transmission Belt (G-05-E540-2-036)				
	d. Kit for MDS Dryer				
	- Filter cartridge 40 µm F05-0204-A				
	- Filter cartridge 1 µm F05-0205-A				
	- Filter cartridge 0,01 µm F05-0206-A				
	e. Kit for CO/HC				
	- Hex socket screw Ig: 20 Inox				
	- Silanized tease glasswool				
	- Palladium on alumina 0,5 %				
	- Converter body P01-0072-G				
	- High temperature Grease				
	- Puckbelleville 16X8.2X0.6				
	f. Kits For D-R 290 Opacity Total Particulate				
	- Filter Cartridge				
	- Hose 1 ½ inch untuk blower, length : 20 M				
	- Hose 2 inch for blower, length : 5 M				
2.	Refill Gas Kalibrasi MESA Environmental Gas Standard.	1	Lot		
	- 330 mg/m3 Sulfur Dioxide				
	- 330 mg/m3 Nitric Oxide				
	- 120 mg/m3 Carbon monoxide				
	- 10% Carbon dioxide				
	- Balance Nitrogen				
	- Certified Standard				
	- Analytical Accuracy +-2%				
	- Blend Tolerance +- 5%				
	- Pressure 2000 PSI				
	- Cylinder A030-HP				
3.	Refill Gas Kalibrasi MESA Environmental Gas Standard.	1	Lot		
	- 110 mg/m3 Sulfur Dioxide				
	- Balance Nitrogen				
	- Certified Standard				
	- Analytical Accuracy +-2%				

	- Blend Tolerance +- 5% - Pressure 2000 PSI - Cylinder A030-HP									
4.	Refill Gas Kalibrasi MESA Environmental Gas Standard. - 10% Oxygen - Balance Nitrogen - Analytical Accuracy +-2% - Blend Tolerance +- 5% - Pressure 2000 PSI - Cylinder A030-HP	1	Lot							
5.	Jasa Pemeliharaan Peralatan CEMS (visit 3 bulan sekali dalam setahun)	1	Lot							
6.	Jasa Kalibrasi Opacity D-R 290-86 seet 4 Testifier Set of our calibration attenuators for linearity	1	Lot							
- Spesifikasi/detail material/jasa pekerjaan dicantumkan di lampiran berikut, - Harga sudah termasuk biaya protokol kesehatan covid-19 (rapid/swab test)				<table border="1" style="width: 100%;"> <tr> <td style="background-color: #ADD8E6;">SUB TOTAL</td><td></td></tr> <tr> <td style="background-color: #ADD8E6;">PPN 11%</td><td></td></tr> <tr> <td style="background-color: #ADD8E6;">TOTAL HARGA</td><td></td></tr> </table>	SUB TOTAL		PPN 11%		TOTAL HARGA	
SUB TOTAL										
PPN 11%										
TOTAL HARGA										