

Lampiran Pengumuman:	266.1.Peng/SCM/PJBS/2023
Tanggal	:20 Februari 2023

**BILL OF QUANTITY (BOQ)**  
**Pengadaan Penggantian Pompa Vacuum PLTU Bolok - WO78874 AI PLN**

No	ITEM BARANG/JASA	Jumlah	Satuan
1.	Jasa Supervisi Pemasangan Vacuum Pump	1	Lot
2.	PUMP, LIQUID RING VACUUM, IN-PRESS 33-1013 HPA, OUT-PRESS 1013 HPA (A), CAPACITY 7.5-18.8 M3/H, TWO STAGE, RATE SPEED 980 RPM, SHAFT POWER 37KW, OPERATING LIQUID 2.0-5.5 M3/H, MATERIAL SS316 (IMPELLER), REF: KENFLOW LIQUID RING VACUUM PUMP TYPE 2BW4 203-OEK	1	Set